



Environmental Hazards Services, L.L.C.  
 7469 Whitepine Rd  
 Richmond, VA 23237  
 Telephone: 800.347.4010

## Lead in Drinking Water Analysis Report

Report Number: 21-08-03938

Client: LEW Corp  
 181 US Hwy 46  
 Mine Hill, NJ 07803

Received Date: 08/25/2021  
 Reported Date: 08/31/2021  
 Sampled By: Krishi Tanna  
 Tech Certification #:

Project/Test Address: 210133; Brooks Crossing @ Deans; 848 Georges Rd; Monmouth Junction, NJ

Client Number:  
 201327

# Laboratory Results

Fax Number:  
 Ext 18 Melissa

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
21-08-03938-001	BCD-B-01	08/06/2021	HALL BY STAIRS L	7.00	08/30/2021	
21-08-03938-002	BCD-B-02	08/06/2021	HALL BY STAIRS R	2.05	08/30/2021	
21-08-03938-003	BCD-B-03	08/06/2021	RM A5	4.63	08/30/2021	
21-08-03938-004	BCD-S-04	08/06/2021	CAFETERIA	1.44	08/30/2021	
21-08-03938-005	BCD-S-05	08/06/2021	KITCHEN L	8.47	08/30/2021	
21-08-03938-006	BCD-S-06	08/06/2021	KITCHEN R	4.66	08/30/2021	
21-08-03938-007	BCD-B-07	08/06/2021	HALL BY A3 L	16.6	08/30/2021	
21-08-03938-008	BCD-B-08	08/06/2021	HALL BY A3 R	11.0	08/30/2021	
21-08-03938-009	BCD-B-09	08/06/2021	RM A1	7.07	08/30/2021	
21-08-03938-010	BCD-B-10	08/06/2021	HALL NEXT TO B3	10.8	08/30/2021	
21-08-03938-011	BCD-B-11	08/06/2021	HALL NEXT TO NURSE	46.9	08/30/2021	
21-08-03938-012	BCD-S-12	08/06/2021	NURSES	2.45	08/30/2021	
21-08-03938-013	BCD-WC-13	08/06/2021	CAFE NEXT TO SINK	<1.00	08/30/2021	

BC 8/25/21

# Environmental Hazards Services, L.L.C

Client Number: 201327  
Project/Test Address: 210133; Brooks Crossing @ Deans; 848 Georges Rd;  
Monmouth Junction, NJ

Report Number: 21-08-03938

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
21-08-03938-014	BCD-S-14	08/06/2021	NEXT TO EXIT	<1.00	08/30/2021	

Method: EPA 200.8  
Analyst: Ailea Cabatbat  
Accreditation #: NJ VA008

Reviewed By Authorized Signatory: *Melissa Kanode*

Missy Kanode

QA/QC Clerk

Sample Results denoted with a "less than" (<) sign contain less than the reporting limit which is 1 ppb.

The EPA Maximum Contaminant Level for Lead in Drinking Water is 15 ppb. The results herein conform to NELAC standards, where applicable, unless otherwise narrated on this report. Results represent the analysis of samples submitted by the client. Sample location, description, field parameter results, etc., were provided by the client. This report cannot be reproduced, except in full, without written approval from Environmental Hazards Services, L.L.C.

LEGEND                      ug/L= micrograms per liter                      ppb = parts per billion



LABORATORIES

ENVIRONMENTAL ANALYTICAL SERVICES, LLC

Water Chain-of-Custody Form

SHIP TO: 7469 Whitepine Rd. Richmond, VA 23237  
Phone: (800) 347-4010; FAX: (804) 275-4907

ONLINE CLIENT PORTAL AVAILABLE FOR ANALYSIS RESULTS AT: www.leadlab.com

21-08-03938  
Due Date:  
09/01/2021  
(Wednesday)  
AE

AK

Company Name: LEW CORP Account #: 201327  
Address: 181 US Highway 45 City/State/Zip: Mine Hill, NJ 07803  
Phone: (908) 654-8068 Email: labresults@lewoor.com Fax: 908-654-8069

Project Name / Collection Address: BROOKS CROSSING @ DEANS, 848 GEORGES RD City/State/Zip: MONMOUTH JUNCTION, NJ  
Project #: 210133 Sampled By: Krishi Tanna License # (if required):  
Water Source: (Check One) Public  Well  Well Tag # (if applicable):

No.	Client Sample ID	Collection Location (Ex: Kitchen Sink)	Collection Date	Collection Time	Metals			Field Parameters	LAB USE
					Lead	Copper	Other		
1	BCD - B - 01	HALL BY STAIRS - L	8/6/2021	10 AM - 10:20 AM	X				
2	BCD - B - 02	HALL BY STAIRS - R	8/6/2021	10 AM - 10:20 AM	X				
3	BCD - B - 03	RM A5	8/6/2021	10 AM - 10:20 AM	X				
4	BCD - S - 04	CAFETERIA	8/6/2021	10 AM - 10:20 AM	X				
5	BCD - S - 05	KITCHEN - L	8/6/2021	10 AM - 10:20 AM	X				
6	BCD - S - 06	KITCHEN - R	8/6/2021	10 AM - 10:20 AM	X				
7	BCD - B - 07	HALL BY A3 - L	8/6/2021	10 AM - 10:20 AM	X				
8	BCD - B - 08	HALL BY A3 - R	8/6/2021	10 AM - 10:20 AM	X				
9	BCD - B - 09	RM A1	8/6/2021	10 AM - 10:20 AM	X				
10	BCD - B - 10	HALL NEXT TO B3	8/6/2021	10 AM - 10:20 AM	X				

Requested by: KRISHI TANNA Signature: *Krishi Tanna* Date/Time: 8/6/2021  
Requested by: *Mr. Amy Vignar* Signature: *Amy Vignar* Date/Time: 8/6/2021  
11:27 AM



ENVIRONMENTAL CHEMISTRY SERVICES, LLC

ONLINE CLIENT PORTAL AVAILABLE FOR ANALYSIS RESULTS AT: www.leadlab.com

### Water Chain-of-Custody Form

SHIP TO: 7469 Wintonhills Rd., Richmond, VA 23237

Phone: (800) 347-4010 FAX: (804) 273-4907

www.leadlab.com

9939

For Lab Use Only

Company Name: LEW CORP Account No. 201327

Address: 100 US Highway 45 City/State/Zip: Mine Hill, NJ 07803

Phone: 908-654-8058 Email: labresults@lewcorp.com Fax: 908-654-8055

Project Name / Collection Address: BROOKS CROSSING @ DEANS, 848 GEORGES RD

City/State/Zip: MONMOUTH JUNCTION, NJ

Project #: 210133 Sampled by: Krishi Tanna

License # (if Required)

Water Source: (Check One) Public  Well  Well Tag # (if Applicable)

X	Client Sample ID	Collection Location (Ex: Kitchen Sink)	Collection Date	Collection Time	Metals			Field Parameters		LAB USE
					Lead	Copper	Other	Field pH at time of Collection	Temp. at time of Collection	
	11	BCD - B - 11 HALL NEXT TO NURSE	8/6/2021	10 AM - 10:20 AM	X					
	12	BCD - S - 12 NURSES	8/6/2021	10 AM - 10:20 AM	X					
	13	BCD - WC - 13 CAFE NEXT TO SINK	8/6/2021	10 AM - 10:20 AM	X					
	14	BCD S 14 NEXT TO EXIT	8/6/2021	10 AM - 10:20 AM	X					
	5				X					
	6				X					
	7				X					
	8				X					
	9				X					
	10				X					

Released by: KRISHI TANNA

Signature: [Handwritten Signature]

Date/Time: 8/6/2021

Date/Time: 8/25/21

Date/Time: 11:27 AM



BC 8/23/21

# Lead in Drinking Water Analysis Report

Environmental Hazards Services, L.L.C.  
7469 Whitepine Rd  
Richmond, VA 23237  
Telephone: 800.347.4010

Report Number: 21-08-03467

Client: LEW Corp  
181 US Hwy 46  
Mine Hill, NJ 07803

Received Date: 08/23/2021  
Reported Date: 08/30/2021  
Sampled By: Krishi Tanna  
Tech Certification #:

Project/Test Address: 210133; Brooks Crossing; 50 Deans Rhode Hall; Monmouth Junction, NJ

Client Number:  
201327

## Laboratory Results

Fax Number:  
Ext 18 Melissa

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
21-08-03467-001	BC-WC-01	08/06/2021	HALL BY WATER R	<1.00	08/24/2021	
21-08-03467-002	BC-WC-02	08/06/2021	HALL BY WATER L	<1.00	08/24/2021	
21-08-03467-003	BC-PF-03	08/06/2021	KITCHEN	1490	08/27/2021	W01
21-08-03467-004	BC-S-04	08/06/2021	NEXT TO POT FILLER	6.32	08/27/2021	W01
21-08-03467-005	BC-S-05	08/06/2021	KTICHEN L	<1.00	08/24/2021	
21-08-03467-006	BC-S-06	08/06/2021	KITCHEN R	1.26	08/24/2021	
21-08-03467-007	BC-S-07	08/06/2021	SINK COMPT	5.18	08/24/2021	
21-08-03467-008	BC-S-08	08/06/2021	MAIN OFFICE	1.41	08/24/2021	
21-08-03467-009	BC-WC-09	08/06/2021	OUTSIDE NURSE HALL	<1.00	08/24/2021	
21-08-03467-010	BC-S-10	08/06/2021	NURSE OFFICE	2.00	08/24/2021	
21-08-03467-011	BC-S-11	08/06/2021	MEDIA CENTER OFFICE	1.92	08/24/2021	
21-08-03467-012	BC-B-12	08/06/2021	RM B202	1.16	08/24/2021	
21-08-03467-013	BC-B-13	08/06/2021	RM B203	<1.00	08/24/2021	

## Environmental Hazards Services, L.L.C

Client Number: 201327  
 Project/Test Address: 210133; Brooks Crossing; 50 Deans Rhode Hall;  
 Monmouth Junction, NJ

Report Number: 21-08-03467

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
21-08-03467-014	BC-B-14	08/06/2021	RM B205	<1.00	08/24/2021	
21-08-03467-015	BC-B-15	08/06/2021	RM B206	1.79	08/24/2021	
21-08-03467-016	BC-B-16	08/06/2021	RM B207	1.33	08/24/2021	
21-08-03467-017	BC-B-17	08/06/2021	RM B208	<1.00	08/24/2021	
21-08-03467-018	BC-B-18	08/06/2021	RM B209	<1.00	08/24/2021	
21-08-03467-019	BC-B-19	08/06/2021	RM C301	1.16	08/24/2021	
21-08-03467-020	BC-B-20	08/06/2021	RM C302	3.00	08/24/2021	
21-08-03467-021	BC-B-21	08/06/2021	RM C303	<1.00	08/24/2021	
21-08-03467-022	BC-B-22	08/06/2021	RM C304	<1.00	08/24/2021	
21-08-03467-023	BC-B-23	08/06/2021	RM C305	2.62	08/24/2021	
21-08-03467-024	BC-B-24	08/06/2021	RM C306	1.17	08/24/2021	
21-08-03467-025	BC-WC-25	08/06/2021	HALL BY RM C307 LEFT	<1.00	08/24/2021	
21-08-03467-026	BC-WC-26	08/06/2021	HALL BY RM C307 RIGHT	<1.00	08/24/2021	
21-08-03467-027	BC-B-27	08/06/2021	RM D400	1.32	08/24/2021	
21-08-03467-028	BC-B-28	08/06/2021	RM D401	1.52	08/24/2021	
21-08-03467-029	BC-B-29	08/06/2021	RM D403	1.05	08/24/2021	
21-08-03467-030	BC-B-30	08/06/2021	RM D405	<1.00	08/24/2021	
21-08-03467-031	BC-B-31	08/06/2021	RM D404	<1.00	08/24/2021	
21-08-03467-032	BC-B-32	08/06/2021	RM D406	1.27	08/24/2021	
21-08-03467-033	BC-B-33	08/06/2021	RM D407	1.26	08/24/2021	

## Environmental Hazards Services, L.L.C

Client Number: 201327  
 Project/Test Address: 210133; Brooks Crossing; 50 Deans Rhode Hall;  
 Monmouth Junction, NJ

Report Number: 21-08-03467

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
21-08-03467-034	BC-B-34	08/06/2021	RM D408	1.13	08/24/2021	
21-08-03467-035	BC-B-35	08/06/2021	RM D411	<1.00	08/24/2021	
21-08-03467-036	BC-B-36	08/06/2021	RM D412	1.10	08/24/2021	
21-08-03467-037	BC-B-37	08/06/2021	RM D413	<1.00	08/24/2021	
21-08-03467-038	BC-B-38	08/06/2021	RM D414	1.27	08/24/2021	
21-08-03467-039	BC-B-39	08/06/2021	RM D415	1.93	08/24/2021	
21-08-03467-040	BC-WC-40	08/06/2021	HALL NEXT TO RM D415 LEFT	<1.00	08/24/2021	
21-08-03467-041	BC-WC-41	08/06/2021	HALL NEXT TO RM D415 RIGHT	200	08/27/2021	
21-08-03467-042	BC-WC-42	08/06/2021	FACULTY DINING	<1.00	08/24/2021	
21-08-03467-043	BC-S-43	08/06/2021	FACULTY DINING	<1.00	08/24/2021	
21-08-03467-044	BC-S-44	08/06/2021	NEXT TO EXIT	<1.00	08/24/2021	

**Sample Narratives:**

W01: MB exceeded acceptance limit for Pb.

Method: EPA 200.8  
 Analyst: Ailea Cabatbat  
 Accreditation #: NJ VA008

Reviewed By Authorized Signatory:

*Melissa Kanode*

Missy Kanode  
 QA/QC Clerk

Sample Results denoted with a "less than" (<) sign contain less than the reporting limit which is 1 ppb.

The EPA Maximum Contaminant Level for Lead in Drinking Water is 15 ppb. The results herein conform to NELAC standards, where applicable, unless otherwise narrated on this report. Results represent the analysis of samples submitted by the client. Sample location, description, field parameter results, etc., were provided by the client. This report cannot be reproduced, except in full, without written approval from Environmental Hazards Services, L.L.C.

LEGEND                      ug/L= micrograms per liter                      ppb = parts per billion



EHSO Laboratories  
ENVIRONMENTAL HAZARDOUS SERVICES, LLC

ONLINE CLIENT PORTAL AVAILABLE FOR ANALYSIS RESULTS AT: [www.leadlab.com](http://www.leadlab.com)

### Water Chain-of-Custody Form

SHIP TO: 7469 Winchester Rd, Richmond, VA 23237  
Phone: (800) 347-4010 FAX: (804) 275-4907



21-08-03467

Due Date:  
08/30/2021  
(Monday)  
AE

Company Name: LEW CORP

Address: 181 US Highway 46

Phone: (908) 654-8068

Email: [labresults@lewcorp.com](mailto:labresults@lewcorp.com)

City/State/Zip: Mine Hill, NJ 07803

Fax: (908) 654-8069

Project Name/Collection Address: BROOKS CROSSING, 50 DEANS RHODE HALL

Project #: 210133

Sampled by: Krishi Tanna

City/State/Zip: MONMOUTH JUNCTON, NJ

License #: (If Required):

Water Source: (Check One) Public  Well

Well Tag #: (If Applicable):

No.	Client Sample ID	Collection Location (Ex: Kitchen Sink)	Collection Date	Collection Time	Metals			Field Parameters			LAB USE Temp at Time of Receipt	
					Lead	Copper	Other	Field pH at time of Collection	Temp. at time of Collection			
1	BC - WC - 01	HALL BY WATER - R	8/6/2021	11 AM - 12:30 AM <sup>PM</sup>	X							
2	BC - WC - 02	HALL BY WATER - L	8/6/2021	11 AM - 12:30 AM <sup>PM</sup>	X							
3	BC - PF - 03	KITCHEN	8/6/2021	11 AM - 12:30 AM <sup>PM</sup>	X							
4	BC - S - 04	NXT TO POT FILLER	8/6/2021	11 AM - 12:30 AM <sup>PM</sup>	X							
5	BC - S - 05	KITCHEN - L	8/6/2021	11 AM - 12:30 AM <sup>PM</sup>	X							
6	BC - S - 06	KITCHEN - R	8/6/2021	11 AM - 12:30 AM <sup>PM</sup>	X							
7	BC - S - 07	SINK COMPT.	8/6/2021	11 AM - 12:30 AM <sup>PM</sup>	X							
8	BC - S - 08	MAIN OFFICE	8/6/2021	11 AM - 12:30 AM <sup>PM</sup>	X							
9	BC - WC - 09	OUTSIDE NURSE HALL	8/6/2021	11 AM - 12:30 AM <sup>PM</sup>	X							
10	BC - S - 10	NURSE OFFICE	8/6/2021	11 AM - 12:30 AM <sup>PM</sup>	X							

Released by: KRISHI TANNA

Signature: *Krishi Tanna*

Signature: *Krishi Tanna*

Date/Time: 8/6/2021

Date/Time: 8 23 21

10:16 AM





ENVIRONMENTAL HAZARD SERVICES, LLC

ONLINE CLIENT PORTAL AVAILABLE FOR ANALYSIS RESULTS AT: [www.leadlab.com](http://www.leadlab.com)

### Water Chain-of-Custody Form

SHIP TO: 7469 Whitepine Rd. Richmond, VA 23237  
Phone: (800) 947-4010 FAX: (804) 275-4907

~ For Lab Use Only ~

Company Name: LEW CORP

Account #: 201322

Address: 183 US HIGHWAY 46

City/State/Zip: Mine Hill, NJ 07803

Phone: (908) 554-8068

Email: [labresults@lewcorp.com](mailto:labresults@lewcorp.com)

Fax: 908-654-8069

Project Name / Collection Address: BROOKS CROSSING, 50 DEANS RHODE HALL

City/State/Zip: MONMOUTH JUNCTION, NJ

Project #: 210133

Sampled by: Krishi Tanna

License # (if Required):

Water Source: (Check One) Public  Well

Well Tag # (if Applicable):

No.	Client Sample ID	Collection Location (Exc. Kitchen Sink)	Collection Date	Collection Time	Metals			Field Parameters		LAB USE Temp at Time of Receipt
					Lead	Copper	Other	Field pH at time of Collection	Temp. at time of Collection	
11	BC-S-11	MEDIA CENTER OFFICE	8/6/2021	11 AM - 12:30 AM <sup>PM</sup>	X					
12	BC-B-12	RM B202	8/6/2021	11 AM - 12:30 AM <sup>PM</sup>	X					
13	BC-B-13	RM B203	8/6/2021	11 AM - 12:30 AM <sup>PM</sup>	X					
14	BC-B-14	RM B205	8/6/2021	11 AM - 12:30 AM <sup>PM</sup>	X					
15	BC-B-15	RM B206	8/6/2021	11 AM - 12:30 AM <sup>PM</sup>	X					
16	BC-B-16	RM B207	8/6/2021	11 AM - 12:30 AM <sup>PM</sup>	X					
17	BC-B-17	RM B208	8/6/2021	11 AM - 12:30 AM <sup>PM</sup>	X					
18	BC-B-18	RM B209	8/6/2021	11 AM - 12:30 AM <sup>PM</sup>	X					
19	BC-B-19	RM C301	8/6/2021	11 AM - 12:30 AM <sup>PM</sup>	X					
20	BC-B-20	RM C302	8/6/2021	11 AM - 12:30 AM <sup>PM</sup>	X					

Released by: KRISHI TANNA

Signature: *[Signature]*

Signature: *[Signature]*

Date/Time: 8/6/2021

Date/Time: 8/23/21 10:46 AM



**LABORATORIES**  
ENVIRONMENTAL HAZARDS SERVICES, LLC

ONLINE CLIENT PORTAL AVAILABLE FOR ANALYSIS RESULTS AT: [www.leadlab.com](http://www.leadlab.com)

### Water Chain-of-Custody Form

SHIP TO: 7469 Whitepine Rd., Richmond, VA 23237

Phone: (800) 347-4010 FAX: (804) 275-4907

~ For Lab Use Only ~

Company Name: LEW CORP

Account #: 201327

Address: 181 US Highway 46

City/State/Zip: Mine Hill, NJ 07803

Phone: (908) 554-8068

Email: [ehsresults@ewcorp.com](mailto:ehsresults@ewcorp.com)

Fax: (908) 654-8068

Project Name / Collection Address: BROOKS CROSSING, 50 DEANS RHODE HALL

City/State/Zip: MONMOUTH JUNCTION, NJ

Project #: 210133

Sampled by: Krishi Tamra

License If (If Required):

Water Source: (Check One) Public  Well

Well Tag # (If Applicable):

No.	Client Sample ID	Collection Location (Etc: Kitchen Sink)	Collection Date	Collection Time	Metals		Field Parameters			LAB USE Temp. at Time of Receipt
					Lead	Copper	Field pH at time of Collection	Temp. at time of Collection		
21	BC-B-21	RM C303	8/6/2021	11 AM - 12:30 AM/PM	X					
22	BC-B-22	RM C304	8/6/2021	11 AM - 12:30 AM/PM	X					
23	BC-B-23	RM C305	8/6/2021	11 AM - 12:30 AM/PM	X					
24	BC-B-24	RM C306	8/6/2021	11 AM - 12:30 AM/PM	X					
25	BC-WC-25	HALL BY RM C307 - LEFT	8/6/2021	11 AM - 12:30 AM/PM	X					
26	BC-WC-26	HALL BY RM C307 - RIGHT	8/6/2021	11 AM - 12:30 AM/PM	X					
27	BC-B-27	RM D400	8/6/2021	11 AM - 12:30 AM/PM	X					
28	BC-B-28	RM D401	8/6/2021	11 AM - 12:30 AM/PM	X					
29	BC-B-29	RM D403	8/6/2021	11 AM - 12:30 AM/PM	X					
30	BC-B-30	RM D405	8/6/2021	11 AM - 12:30 AM/PM	X					

Released by: KRISHI TANNA

Signature: *[Signature]*

Date/Time: 8/6/2021

Released by: KRISHI HARRIS

Signature: *[Signature]*

Date/Time: 8/23/21 10:46am



LABORATORIES  
ENVIRONMENTAL HAZARDS SERVICES, LLC

ONLINE CLIENT PORTAL AVAILABLE FOR ANALYSIS RESULTS AT: [www.leadlab.com](http://www.leadlab.com)

### Water Chain-of-Custody Form

SHIP TO: 7469 Whitepine Rd., Richmond, VA 23237

Phone: (800) 347-4010 FAX: (804) 275-4907

~ For Lab Use Only ~

Company Name: LEW CORP

Account #: 201327

Address: 181 US Highway 46

City/State/Zip: Mine Hill, NJ 07803

Phone: (908) 554-8069

Email: [labresults@lewcorp.com](mailto:labresults@lewcorp.com)

Fax: 908-654-8069

Project Name / Collection Address: BROOKS CROSSING, 50 DEANS RHODE HALL

City/State/Zip: MONMOUTH JUNCTION, NJ

Project #: 210133

Sampled by: Krishi Tanna

License # (if required):

Water Source: (Check One) Public  Well

Well Tag # (if applicable):

No.	Client Sample ID	Collection Location (ex: Kitchen Sink)	Collection Date	Collection Time	Metals			Field Parameters			LAB USE Temp at Time of Receipt	
					Lead	Copper	Other	Field pH at time of Collection	Temp. at time of Collection			
31	BC - B - 31	RM D404	8/6/2021	11 AM - 12:30 AM <sup>PM</sup>	X							
32	BC - B - 32	RM D406	8/6/2021	11 AM - 12:30 AM <sup>PM</sup>	X							
33	BC - B - 33	RM D407	8/6/2021	11 AM - 12:30 AM <sup>PM</sup>	X							
34	BC - B - 34	RM D408	8/6/2021	11 AM - 12:30 AM <sup>PM</sup>	X							
35	BC - B - 35	RM D411	8/6/2021	11 AM - 12:30 AM <sup>PM</sup>	X							
36	BC - B - 36	RM D412	8/6/2021	11 AM - 12:30 AM <sup>PM</sup>	X							
37	BC - B - 37	RM D413	8/6/2021	11 AM - 12:30 AM <sup>PM</sup>	X							
38	BC - B - 38	RM D414	8/6/2021	11 AM - 12:30 AM <sup>PM</sup>	X							
39	BC - B - 39	RM D415	8/6/2021	11 AM - 12:30 AM <sup>PM</sup>	X							
40	BC - WC - 40	HALL NEXT TO RM D415 - LEFT	8/6/2021	11 AM - 12:30 AM <sup>PM</sup>	X							

Released by: KRISHI TANNA

Signature: *[Signature]*

Signature: *[Signature]*

Date/Time: 8/6/2021

Date/Time: 8/23/21 10:46am



LEAD SOLUTIONS  
ENVIRONMENTAL HAZARDS SERVICES, LLC

ONLINE CLIENT PORTAL AVAILABLE FOR ANALYSIS RESULTS AT: [www.leadlab.com](http://www.leadlab.com)

### Water Chain-of-Custody Form

SHIP TO: 7469 Whitepine Rd. Richmond, VA 23237

Phone: (800) 347-4010 FAX: (804) 275-4907

~ For Lab Use Only ~

Company Name: LEWL CORP

Account #: 201327

Address: 181 US Highway 46

City/State/Zip: Mine Hill, NJ 07003

Phone: (908) 654-8068

Email: [labresults@lewlcorp.com](mailto:labresults@lewlcorp.com)

Fax: 908-654-8069

Project Name / Collection Address: BROOKS CROSSING, 50 DEANS RHODE HALL

City/State/Zip: MONMOUTH JUNCTION, NJ

Project #: 210133

Sampled by: Krishi Tanna

License # (If Required):

Water Source: (Check One) Public  Well

Well Tag # (If Applicable):

No.	Client Sample ID	Collection Location (Ex: Kitchen Sink)	Collection Date	Collection Time	Metals		Field Parameters		LAB USE Temp at Time of Receipt:
					Lead	Copper	Field pH at time of Collection:	Temp. at time of Collection:	
41	BC - WC - 41	HALL NEXT TO RM D415-RIGHT	8/6/2021	11 AM - 12:30 AM PM	X				
42	BC - WC - 42	FACULTY DINING	8/6/2021	11 AM - 12:30 AM PM	X				
43	BC - S - 43	FACULTY DINING	8/6/2021	11 AM - 12:30 AM PM	X				
44	BC - S - 44	NEXT TO EXIT	8/6/2021	11 AM - 12:30 AM PM	X				
5									
6									
7									
8									
9									
10									

Released by: KRISHI TANNA  
*KRISHI TANNA*

Signature: *KRISHI TANNA*

Signature: *STACY BLAUW*

Date/Time: 8/6/2021

Date/Time: 8/29/21 10:46 AM